



NOTES:
 ALL DIMENSIONS IN MM UNLESS OTHERWISE STATED.
 FUEL STORE CONSTRUCTION TO BE GENERALLY TO DRAWING No STD/017 AND FREE FROM MOISTURE INGRESS.

BOILER ROOM TO BE LINED WITH HALF HOUR FIRE RESISTANT MATERIAL ON ANY COMBUSTIBLE SURFACES, AND FREE FROM MOISTURE INGRESS, AND FLOOR FLAT, SOLID & EVEN.

NO ELECTRICAL EQUIPMENT, LIGHTS ETC TO BE WITHIN FUEL STORE AREA.

ELECTRICAL SUPPLY AND MAINS WATER TO BE SUPPLIED TO BOILER ROOM.

BOILER ROOM WILL REQUIRE A FRESH/COMBUSTION AIR SUPPLY FROM ATMOSPHERE. 850MM² PER KW.

MK	REVISIONS	DRN	CHK	APP	DATE
B	IMPACT MAT REVISED	NDP	MB	MN	14/11/15
A	FIRST ISSUE	NDP	MB	MN	28/09/15

DAWLISH LEISURE CENTRE FLUE LAYOUT

2 x 250kW GUNTAMTIC PRO BOILERS
WITH 2 x 8000 ltr BUFFER TANKS

FOR INFORMATION

ORIGINAL DRAWING SIZE A3 SCALE NTS

DRAWING NUMBER T632 - 002	REV. B
------------------------------	-----------

Tresco Ltd,
 Pyramid House
 1 Tiverton Way
 Tiverton Business Park
 Tiverton
 Devon
 EX16 6TG

Tel. 0845 1 30 90 12
 Web : www.tresco.co.uk
 e-mail : info@tresco.co.uk