


NOTE:
50x50 RHS BOX SECTION STUDS
AND CROSS MEMBERS TO BE
FULL WELD CONSTRUCTION AND
AT CENTRES NECESSARY FOR
STRUCTURAL INTEGRITY.

ELEVATION.

ELEVATION B-B.

PLAN.



NOTES:
ALL DIMENSIONS IN MM UNLESS OTHERWISE STATED.



J	FUEL LEVEL SENSOR MOUNTING POINT SHOWN	AWO	DSM	04/08/15
I	SCALE ALTERED. SCALE BAR ADDED	DB	AT	02/12/14
H	OIL BOILER FUE DRAYOUT STABILISER	DB	AT	25/11/14
G	OIL BOILER FUE HEIGHT	DB	AT	19/11/14
F	OIL BOILER AND FUE DETAILS	DB	AT	17/11/14
E	RESPONSIBLY FOR STABOIL OIL BOILER	JWL	AT	03/11/14
D	FUE SHOWN TO PROPOSED OIL BOILER	JWL	AT	21/10/14
C	OPERATION AND LAYOUT REPAIR	JWL	AT	10/10/14
B	FUE REPORTS IMPACTED	RJC	AT	22/08/14
A	FIRST ISSUE	RJC	AT	14/05/14
MK	REVISIONS	DRN	CHK	APP
				DATE

SANDROYD SCHOOL, SP5 5QD

GUNTAMATIC 198KW BIOCUM CASCADE
C/W OIL BOILER BACK-UP
5000 LTR BUFFER TANK CONTAINERISED

LAYOUT OF PLANT ROOM AND FUEL
STORE IN 40FT HIGH CUBE CONTAINER.

ORIGINAL DRAWING SIZE A3 SCALE: 1:100

DRAWING NUMBER
SANDROYD LAYOUT - 003

REV. J



TRECO Ltd,
Pyramid House
1 Tiverton Way
Tiverton Business Park
Tiverton
Devon
EX16 6TG

Tel. 0845 1 30 90 12
Web : www.tresco.co.uk
e-mail : info@tresco.co.uk